

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 203

Dated: 25/03/2026

It is certified that an inspection team headed by **Dr. Brijesh C. Shah** (Name of Officers with designation) from **Primary Health Centre – Vahelal PHED** inspected the **Satdham Vidyamandir, Village Pardhol, Behind Zank Bus Stand, Naroda-Dahegam Road, Ahmedabad 382330** (Name & Address of the school) on 25/03/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. MIR/MSMERS/203 dated 21/3/2026 of MIR/MSMERS/203 (PHED MIR/MSMERS/203 of MSMERS, Saloo, Ahmedabad. Lab) MIR/MSMERS/203 certified that the **Satdham Vidyamandir** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31/03/2027

Signature with Seal: RCB
Name: DR. BRIJESH C. SHAH
Designation: MIR/MSMERS/203
Name & Address of the Office / Department: MIR/MSMERS/203

To
**Satdham Vidyamandir, Village
Pardhol, Behind Zank Bus Stand,
Naroda-Dahegam Road,
Ahmedabad 382330**

MIR/MSMERS/203
Medical Officer
P.H.C., Vahelal,
Ta. Daskroi.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PRIMARY HEALTH CENTRE - VAHELAL

Village -Vahelal,Ta-Draskroi,Distt-Ahmedabad

E-mail - phcvahelal.health.ahmedabad2@gmail.com

Date-1/4/2026

To,

Satdham Vidhyamandir

Village -Pardhol

Ta.Draskroi

Dis.Ahmedabad

DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is Certified that Inspection team headed by Dr. Brijesh.c.Shah (Medical officer) From Primary Health Centre -Vahelal Inspected the Satdham Vidhyamandir, at Po.Pardhol village,Ta - Draskroi, Dis.Ahmedabad.On 25/3/26 found that the Satdham Vidhyamandir is maintaining the hygienic sanitation condition in the school building and also have water purifying unit which supply pure and safe drinking water to the entire school building and the campus is per the norms prescribed by the centre/state/U.T.Gov.

The above valid upto 31/3/27

Medical officer

PHC Vahelal B.C.S

મેડીકલ ઓફીસર

પ્રા. આ. વેલ-વહેલાલ

તા. દરાસ્ક્રોઈ, જિ. અમદાવાદ

To,

Department Of Microbiology ,GMERS Medical College &
General Hospital, Sola, Ahmedabad

Type of sample- Drinking Water

Outward/Micro/GMERS/No. /26

Investigation- Water culture for Fecal Coliform bacteria
Sample received on:18/03/2026
Method of Investigation: MPN by multiple tube count
Date Of Result: 21/03/2026

293

Sample received from - PHC VAHELAL

Lab no	Sample From	Results	Interpretation
W-404/26	BORMATHI LIDHEL PANI	Fecal E.Coli is not detected. MPN per 100 ml is 0 after 48 hours	SATISFACTORY
W-405/26	TANKIMATHI LIDHEL PANI	Fecal E.Coli is not detected. MPN per 100 ml is 0 after 48 hours	SATISFACTORY
W-406/26	NALMATHI LIDHEL PANI	Fecal E.Coli is not detected. MPN per 100 ml is 0 after 48 hours	SATISFACTORY

INTERPRETATION CRITERIA:-

Organisms	Colony count (MPN/100 ml)	Interpretation	Action
Organisms detected in drinking water (Multiple tube method)			
Coliform other than Fecal E. coli	0	Excellent	No action is required
	1-3	Satisfactory	Resample
	4-10	Suspicious	-Resample and review water disinfection process
	> 10	Unsatisfactory	-Review of infection control measures -Stop using the water for drinking purposes and hospital use -Consider disinfection of water distribution system
Fecal E. coli	0	Satisfactory	-No action is required
	> 0	Unsatisfactory	-Review of control measures -Stop using the water for drinking purposes and hospital use -Disinfection of water distribution system

Ⓢ

Microbiologist
Professor

Department of Microbiology
GMERS

Medical College, Sola, Ahmedabad

For [Signature]

PROFESSOR & HEAD OF DEPARTMENT MICROBIOLOGY

Prof. & Head of Microbiology Dept
GMERS Medical College & Hospital
Sola, Ahmedabad-380 050.(Guj.)